


# Particle Size Distribution Report



% COBBLES 0.0	% GRAVEL 53.3	% SAND 42.6	% SILT 4.1	% CLAY 4.1
------------------	------------------	----------------	---------------	---------------

SIEVE SIZE	PERCENT FINER	SPEC.* PERCENT	PASS? (X=NO)
2 in.	100.0		
1.5 in.	96.2		
1 in.	88.1		
3/4 in.	79.5		
3/8 in.	59.6		
#4	46.7		
#10	37.3		
#20	26.7		
#40	17.7		
#50	12.9		
#100	6.8		
#200	4.1		

\* (no specification provided)

**Material Description**

RECYCLED MATERIAL

PL=                      **Atterberg Limits**                      PI=

LL=                      **Coefficients**                      D<sub>50</sub>= 5.92

D<sub>85</sub>= 22.8                      D<sub>60</sub>= 9.68                      D<sub>10</sub>= 0.231

D<sub>30</sub>= 1.10                      C<sub>c</sub>= 0.54

C<sub>u</sub>= 42.00

USCS=                      **Classification**                      AASHTO=

**Remarks**

Sample No.: 195  
Location:

Source of Sample: AGRETECH, 3" MINUS RECYCLED

Date: 7/06/2010  
Elev./Depth:

<p><b>UTS OF MASSACHUSETTS, INC.</b> 5 Richardson Lane Stoneham, MA 02180</p>	<p>Client: AGRETECH Project: Project No:                      Figure 195</p>
---	--